# ATLANTIS®

### Main Specifications

▼ Size

4″,6″

▼ Window

Safety glass

### ▼Pressure connection

Material: SS316 Welded / O-ring sealed Thread size: 1/4", 3/8", 1/2" Thread type: BSPT, NPT, PF

#### ▼ Pressure range

Gauge pressure ▼ 0...400 to 10000mmH<sub>2</sub>O Negative pressure ▼ -1...0bar / -76...0cmHg Compound pressure ▼ -1...0 to 10000mmH<sub>2</sub>O

#### ▼Applicable fluid

Liquid and gas that compatible with connection's material

✓ Ambient temperature
-20°C to +60°C
✓ Fluid temperature

+100°C ▼Liquid-filling (For pressure range over 2500mmH<sub>2</sub>O) Glycerin

▼Temperature drift 20°C as standard, every ±8°C max. error: ±0.5% F.S. ▼Protection level

IP54 (standard) / IP65 (option) ▼Explosion-proof level Exib II CT6

### **Other Specifications**

▼ Ring material
 Stainless steel
 ▼ Ring mount
 Outside bayonet
 Adjustable set point
 ▼ Case material
 SS 304

▼Wiring type

Concealed magnet base with junction box

▼ Switch contact type Inductive Switch SPST (NC / NO)

### ▼Contact function

Single contact N.O. (1a)/ Single contact N.C. (1b)/ Double contacts N.O.+N.C. (1a1b) / Double contacts N.O.+N.O. (1b1a) / Double contacts N.O.x2 (2a) / Double contacts N.C.x2 (2b) For more information please refer to single / double contacts wiring ▼ Number of contact SPSTx1 / SPSTx2 / SPSTx4

#### ▼Contact material

80% silver, 20% nickel, 10µm gold-plated (>110V) Gold (≦36V) ▼Pointer

Aluminum with black enamel ▼ Dial face

Red and black scale Pressure unit, scale, and color can be customized upon request

Measuring elements
Diaphragm

Material: SS316 Protection design (option)

Install a blow out back (Only available for 4")

▼ Movement

Stainless steel

- ▼Gauge accuracy ±2.5%F.S. (standard)
- ±1.6%F.S. (option)
- ±1.0%F.S. (option)
- ▼ Set point accuracy
- ±4.0%F.S.

▼Max operating voltage380VAC / 220VDC

- ▼Max current1A
- ▼Contact capacity 30VA

▼Operating pressure Stabilization: 3/4\* F.S. Fluctuation: 3/4\* F.S. Impulse: 1\* F.S.

# Explosion-proof Micro Pressure Gauge with Switch Contact (Inductive Switch Type) Model: ECI-LP Introduction

ECI-LP pressure gauge with inductive switch adopts diaphragm as measuring elements, which is suitable for micro pressure measurement. When pressure increase/decrease to set point, the contact will makes/breaks to control and alarm the connected facility.



Due to the variety of customization, the picture is only for reference, please confirm the actual item with our sales. (If there is any change on specification, please take the latest version as standard.)


## Features

OEM service


- Adopts SPST explosion-proof inductive switch Contact for 4" /6" pressure gauge
- Non-contact type switch, comply with Explosion-proof level Exib II CT6
- Specially designed for measuring micro pressure
- Liquid-filled available, protection level IP65

# **ATLANTIS**<sup>®</sup>

## Contact wiring type




## Single contact N.O. (1a)




Single contact N.C. (1b)

Double contacts								
$\frac{1}{2} + \frac{1}{4} + \frac{1}{2} + \frac{1}{4} + \frac{1}$	When the pressure indicator reaches left set point (green pointer), "1" contact breaks (circuit open); When the pressure indicator reaches right set point (red pointer), "2" contact makes (circuit close) (NC+NO) <positive left→right="" pressure:=""> Switch mode: SPST X 2</positive>	1a1b						
$\stackrel{?}{=} 2 \stackrel{A}{4} \stackrel{1}{1} \stackrel{A}{4} \stackrel{2}{4} \stackrel{2}{4} \stackrel{A}{4} \stackrel{A}{4} \stackrel{A}{4} \stackrel{A}{4} \stackrel{A}{4} \stackrel{A}{4} \stackrel{Black}{} \stackrel{Power}{} \stackrel{C}{} \stackrel{Red}{} \stackrel{Load}{} \stackrel{A}{} \stackrel$	When the pressure indicator reaches left set point (red pointer), "1" contact makes (circuit close) When the pressure indicator reaches right set point (green pointer), "2" contact breaks (circuit open) (NO+NC) <positive left→right="" pressure:=""> Switch mode: SPST X 2</positive>	1b1a						
$ \begin{array}{c} \begin{array}{c} \begin{array}{c} \begin{array}{c} \begin{array}{c} \begin{array}{c} \end{array}\\ \end{array}\\ \end{array}\\ \end{array} \\ \end{array} \\ \begin{array}{c} \end{array} \\ \end{array} \\ \end{array} \\ \begin{array}{c} \end{array} \\ \end{array} \\ \begin{array}{c} \end{array} \\ \begin{array}{c} \end{array} \\ \end{array} \\ \begin{array}{c} \end{array} \\ \begin{array}{c} \end{array} \\ \begin{array}{c} \end{array} \\ \end{array} \\ \begin{array}{c} \end{array} \\ \begin{array}{c} \end{array} \\ \begin{array}{c} \end{array} \\ \end{array} \\ \begin{array}{c} \end{array} \\ \begin{array}{c} \end{array} \\ \end{array} \\ \begin{array}{c} \end{array} \\ \begin{array}{c} \end{array} \\ \end{array} \\ \begin{array}{c} \end{array} \\ \end{array} \\ \begin{array}{c} \end{array} \\ \begin{array}{c} \end{array} \\ \begin{array}{c} \end{array} \\ \end{array} \\ \begin{array}{c} \end{array} \\ \begin{array}{c} \end{array} \\ \end{array} \\ \end{array} \\ \begin{array}{c} \end{array} \\ \end{array} \\ \begin{array}{c} \end{array} \\ \end{array} \\ \end{array} \\ \begin{array}{c} \end{array} \\ \end{array} \\ \end{array} \\ \begin{array}{c} \end{array} \\ \end{array} \\ \end{array} \\ \end{array} \\ \end{array} $ \left\begin{array}{c} \end{array} \\ \end{array} \\ \end{array} \\ \end{array} \\ \end{array} \\ \end{array} \\ \end{array}  \left\begin{array}{c} \end{array} \\ \end{array} \\ \end{array} \\ \end{array} \\ \end{array} \\ \end{array} \\ \end{array}  \left\begin{array}{c} \end{array} \\ \end{array} \\ \end{array} \\ \end{array} \\ \end{array} \\ \end{array}  \left\begin{array}{c} \end{array} \\ \end{array} \\ \end{array} \\ \end{array} \\ \end{array}  \left\begin{array}{c} \end{array} \\ \end{array} \\ \end{array} \\ \end{array} \\ \end{array}  \left\begin{array}{c} \end{array} \\ \end{array} \\ \end{array} \\ \end{array} \\ \end{array}  \left\begin{array}{c} \end{array} \\ \end{array} \\ \end{array} \\ \end{array}  \left\begin{array}{c} \end{array} \\ \end{array} \\ \end{array} \\ \end{array}  \left\begin{array}{c} \end{array} \\ \end{array} \\ \end{array}  \left\begin{array}{c} \end{array} \\ \end{array} \\ \end{array} \\ \end{array}  \left\begin{array}{c} \end{array} \\ \end{array}  \left\begin{array}{c} \end{array} \\ \end{array} \\ \end{array} \\ \end{array}  \left\begin{array}{c} \end{array} \\ \end{array}  \left( \\ \end{array}  \left) \\ \end{array}  \left( \\ \end{array}  \left) \\ \end{array}  \left( \\ \end{array}  \left) \\ \end{array}  \left) \\ \end{array}  \left) \\ \end{array}  \left( \\ \end{array}  \left) \\ \end{array}  \bigg) \\ \end{array}  \left) \\ \end{array}  \left) \\ \end{array}  \left) \\ \end{array}  \bigg) \\ \end{array}  \left) \\ \end{array}  \bigg) \\ \bigg)  \left) \\ \end{array}  \bigg) \\ \end{array}  \bigg) \\ \bigg)  \bigg) \\ \bigg) \\ \end{array}  \bigg) \\ \bigg)  \bigg) \\ \end{array}  \bigg) \\ \bigg) \\ \bigg)  \bigg) \\ \bigg) \\ \bigg) \\ \bigg)  \bigg) \\ \bigg) \\ \bigg)  \bigg) \\ \bigg) \\ \bigg) \\ \bigg) \\ \bigg)  \bigg) \\ \bigg) \\ \bigg) \\ \bigg) \\ \bigg)  \bigg) \\	When the pressure indicator reaches left set point (yellow pointer), "1" contact makes (circuit close) When the pressure indicator reaches right set point (red pointer), "2" contact makes (circuit close) (NO x 2) <positive left→right="" pressure:=""> Switch mode: SPST X 2</positive>	2a						
$ \begin{array}{c} & & & & \\ & & & \\ & & $	When the pressure indicator reaches left set point (green pointer), "1" contact breaks (circuit open) When the pressure indicator reaches right set point (yellow pointer), "2" contact breaks (circuit open) (NC x 2) <positive left<math="" pressure:="">\rightarrowright&gt; Switch mode: SPST X 2</positive>	2b						

# Installation type





### Installation type-size table

Installation type	4″	6″
A	•	•
В	•	
BDE	•	•

### How to order

ECI-LP E	xplosion-pro	oof Micr	o Pressure Gau	ge with	Switch Contact	(Induct	ive Switch Type)			
Std.	Spec.	Code	ltem	Code	ltem	Code	Item	Code	ltem	
04	Size	04	4″	06	6″	-	-	-	_	
1a1b	Contact	1a	N.O.	1b	N.C.	1a1b	N.O.+N.C.	1b1a	N.C.+N.O.	
Tatu	function	2a	N.O.x2	2b	N.C.x2	-	_	-	_	
2	Number of contact	1	SPSTx1	2	SPSTx2	4	SPSTx4	_	_	
316	Connection material	316	SS316	0	Others	-	_	-	-	
316	Diaphragm material	316	SS316	0	Others	_	_	_	_	
2	Thread size	2	1/4″	3	3/8″	4	1/2″	0	Others	
N	Thread type	Р	BSPT	Ν	NPT	F	PF	0	Others	
Custom	Pressure range	Gauge pressure▼ 0…400 to 10000mmH₂O Negative pressure▼ -1…0bar / -76…0cmHg Compound pressure▼ -1…0 to 10000mmH₂O Customized pressure unit (inHg, mmHg, cmHg, etc…), single / dual scale								
c	Accuracy	А	±1%	В	±1.6%	C	±2.5%	_	_	
						-				
		/A	Third party notarized documents			/B	Inspection report			
		/C	Tag			/D	Customized dial face (scale, color, unit, etc.)			
		/E	Install a diaphragm seal         Diaphragm with PTFE coating			/F	Filled with insulating oil			
	Other						(For pressure range >2500mmH <sub>2</sub> O only)			
/D	requests	/G				/H	Internal stop pin for overpressure protection			
		/I				/J	Epoxy coating			
				000		13	-p			
		/K	Install a blow out			/L	Case material SS316	j		

Others: ECI-LP - 04 - 1a1b - 2 - 316 - 316 - 2 - N - (0...10bar) - C + /D